

REF ROVARA: P&D: Tender:2022-23

Date: 02.11.2023

Tender for Furnishing LAN Cabling & Electric Work of Branch Soyepur, Region-Varanasi

Baroda U. P. Bank, Regional Office Varanasi invites sealed tender for <u>Furnishing LAN Cabling & Electric Works for our branch Soyepur, Varanasi.</u>

Imp. Schedules-

405

 $._{\frac{1}{2}} = \frac{h_{12}}{2}$

01. Tender Issue Date-02.11.2023 02 Last Date of Submission of Quotations/Tender 16.11.2023 upto 03.00 p.m. 03. Date of Opening Tender-16.11.2023 at 04.00 p.m. The Regional Manager, 04. Tender to be addressed to-Baroda U.P. Bank, Regional Office-Varanasi J12/140 D-1, Gulab Badi, Chauka Ghat, Varanasi- 221001 (U.P.) 05. Commencement of workwithin 5 days of issue of letter of intent/ order. 06. Period of completion-20 days from the date of issue of intent / order. 07. Retention money/deposit-10 % of gross value from each running bill. 08. Defects liability period-12 months after completion of works. 09. Income tax deduction-At the Prevailing Rates from each bill. 10. Period of running bill-Fortnightly. 11. Period Of Final Measurement-3 weeks from completion/ date of submission of

Terms & Condition-

 Rates Should be quoted on the space provided int the annexures attached only. No other sheet/ form should be used for quoting rates.

final bill, whichever is later.

- 02. Rates quoted only by bank's empanelled vendor will be consider/accepted.
- 03. The competent Authority (bank) does not buying themselves to accept the lowest or to give any reasons for its decision of acceptance or rejection of tenders.
- Incomplete in any respect or conditional tender will not be accepted at all.
- 05. If any clarification is required the same must be obtained before submitting the tender.
- The entire tender document must be duly signed and stamped as a mark of acceptance of the terms and conditions.
- 07. Bank's decision will be final and no correspondence will be entertained in this regards
- 08. In case of delay in submission/no submission of bid, Bank will not assume any resposibility.
- 09. Bank may reject any or all quotations without assigning any reasons.

क्षेत्रीय कार्यालय, जे-12 / 140-डी-1. 'गुलाब बाड़ी, चौकाघाट, वाराणसी-221001 दूरभाष:0542-2201094 Regional Office. J-12/140-D-1, Gulab Badi, Chaukaghat, Varanasi-221001, Telephone: 11542-2201094 e-mail: ROVARA@barodauprrb.co.in



Tender Submission-

1200

Submission of tender in sealed envelope scribing "tender for Furnishing Electric works & data cabling of Branch Soyepur, Varanasi" addressed to Baroda U.P. Bank, J 12/140-D-1, Gulab Badi. Chaukaghat. Varanasi-221001 complete in all respect by 03.00 p.m. Dated 16.11.2023. Tenders received after shall not be entertained.

Tender must be submitted through either by hand or registered post.

Evaluation Of tender-

Quoting incredibly low value of items with the view of subverting the tender process shall be rejected straight away.

Thanking You,

(D.K. Tiwari)

Chief Manager

क्षेत्रीय कार्यालय, जै-12/140-डी-1, गुलाब गाड़ी, चीकाघाट, वाराणसी-221001,दूरमाय:0542-2201094 Regional Office: J-12/140-D-1, Gulab Badi, Chaukaghat, Varanasi-221081,Telephone: 0542-2201094 e-mail: ROVARA@barodauprib.co.in

Schedule of Quantity Tender for furnishing work of Baroda U.P. Bank Soyepur, Branch Dist-Varanasi R.O. Varanasi

S.No. Items of work

Qty Unit Rate Amount.(Rs.)

19mm thick Board with drawer unit and Front side
19mm thick Etching Glass supported with teak
Wood Or Aluminium member with 1.0mm thick
Laminate on the top & drawer unit shall be
Provided on one side while with space for CPU
By its side. Pull out tray on slide shall be
Provided on each counter for keeping keyboard.
All the exposed edges shall have 6 mm th. TW
Lapping duly polished. Inside surface shall be
Enamel painted two coats over primer coats. It
Shall be locks & handles etc. Provision for wire
Management shall be made. Complete work as
Per branch Manager/Architect Satisfaction.

21.00 Rft.

2. P/F of Bank Cash Counter in partition two level Cash counter 5'-0" long (with 3'-10" and 2'-6" Height) counter for customer to be 1'-6" wide And counter to be 3'-0" wide with drawer unit Made out of 19mm thick board with 1.0mm thick Laminate on top and front and other internal Surface to be painted/Polished complete as per Item no. 1

7'-00" Rft.

 P/F of Cash cabin partition front-over the counter Supported on 2'x1-1/2" sal- wood frame work



Cover with 8.0 mm thk. Etching glass supported of 1"x1/2" beading with book window in size 5"x6"

Center of the counter with 2"x2" spacing aluminium

Grill will be fixed in front of

Partition side partition supported 2"x1-1/2" sal

Wood well seasoned structure with a cost of anti

Termite treatment up to 3'-0" height framing of

Inside area with 2"x1-1/2" sal wood section

2'-0"c/c horizontal and vertical with both side

6mm thick ply & 1.0mm thick laminates both side.

The upper portion up to 4'-0" height shall be of

2-1/2"x2"x2-1/2" Aluminum grill will be fixed

Complete with all accessories and labour. 192.00 Sft.

4. P/F of B.M Cabin Low Ht. (4'-6'* High) partly glazed Laminated portion in AdvanceManager/R.D.O Cabin The under framing shall be of 2''x2'' sal wood (Anti termite Treatment) for under framing at 'A max. Distance of 2' in each direction. 6mm th. Waterproof ply shall be fixed on two side and Imm the laminated shall be pasted over it with B Chemical adhesive. Provision shall be made for Passage of electric / data cable and switch board. T.W molding melamine polished shall be fixed Wherever necessary. Bottom 4'' width shall Have skirting upper 1'-6'' height shall have 5mm th. Plane glass.

164.00 Sft.

5. P/F of Low Ht. (4'-6'' High) Laminated portion
For UPS Space The under framing shall be of
2''x2''sal wood (Anti termite Treatment) for
Under framing at a max. distance of 2' in each



	Direction . 6mm th. Waterproof ply shall be		
	Fixed on two side and 1 mm the laminated shall		
	.Be pasted over it with chemical adhesive.	42	Sft,
6.	P/F Low ht. partition Wicket gate &Other		
	Side Partition all Specification as item No. 4.	14.00	Sft.
7.	Providing and fixing in position double leaf		
	Powder coated Aluminium entrance door		
	Made of 14 guage thick sheet. All member		
	Shall be of 4"x1-3/4" section and bottom		
	Rail shall be of 5"x1-3/4" section with 6mm		
	Thick clear sheet glass including 4" dia 2.0		
	Nos handles 10" long 2.0 Nos, Tower bolts,		
	Floor spring 2.0 Nos lock etc. complete.	102.0	Sft.
8.	P/F Godrej Night latch.	2.0	Nos.
9.	P/F f Godrej mortic lock	2.0	No
10.	P/F of Door closer I.S.I mark	4.0	No.
11.	Providing and fixing Writing desk in		
	Position box type Wooden writing in public		
	Space of approximate size 4'-0" x 2'-0"		
	Made out of 19mm thick good approved		
	Quality ply with 6" to 9" wide pigeon hole		
	Type compartments in the front façade boxing		
	For keeping pay-in-ship, book literature etc.		
	.These writing table's must have laminates		
	1.0 mm thick on top writing desk and two side		
	of the boxes. With beeding lipping, moulding		
	and painting / polishing complete.	1.0	No.
12.	Suggestion Box	1.0	No.
13.	Check drop Box	1.0	No.



14. Providing and fixing Aluminum grill in cash Cabin Grill size 2-1/2"x2"x2-1/2" will be Fixed complete with all accessories & labour.

42.0 Sft.

Of approximate size 3'-0" x 2'-0" and 6" deep
Made out of 19mm thick ply with fully glazed
Shutter in front and soft board with felt cloth
Lining at the back inclusive of good approved
Quality lock to this shutter, hinges, fixtures,
Handle etc. and front laminate/painted complete
As directed by bank architect.

1.0 No.

16. Providing and Fixing in position side units

Made out of 19mm board with 1.0 mm

Laminate with slidding hinged shutters

(made out of 12mm thick ply with 1.0 mm

Thick laminate on it) complete with handles

Etc. Size 4'-0'' x 1'-6''' x 2'-6''

2.0 No.

Providing and fixing Column/Wall paneling
 Paneling all specification as per item no. 4

96.00 Sft.

18. Providing and fixing in position Branch

Manager Table (Size 6'-0" x 3'-0") made

Out of 19mm thick water proof board with

1.0 mm th. Laminated on all exposed surface
(others external surface shall be painted with

Two coats of enamel paint over one coat of
Primer) It shall have one unit on one side while

Provision to be made for pull out tray on slides.

The table to be finished in TW/H,W Lipping &
Godrej lock, handles footrest, latches all Complete.

I.0 No.



- 19. Providing and Fixing in position Officer

 Table (Size 5;-0' 'x2'-6'')made out of 19mm.

 Thk. Water proof board with 1.0 mm. th.

 Laminated on all exposed surface (others external Surface shall be painted with two coats of enamel Paint over one coat of primer) It shall have one

 Unit on one side while.
- 20. Providing & fixing wooden Filling Cabinet 1*-6"deep to be fixed on the wall frame made out of 19mm thick commercial ply with siding hinge shutters made out of 12mm thick ply with 1.0mm laminate on the front & side other other inernal surface to be painted as complete with handle, lock, wall catches etc.

96.00 sft

No.

21. False Ceiling (Armstrong) Providing and fixing in position false ceiling in armstrong 600 x 600 x 15/16 mm dune supreme RH 99 prima tile with regular edge frame work as specified by armstrngcompany with suspenders making necessary frame work for A.C. Ducting for diffusers and light fitting.

775.00 Sft.

22. False Ceiling (Gypsum) Providing & fixing with necessary scaffolding frame in 22 guage GI channel /angle, placed at appropriate grid, fixed to RCC slab, beam, wall etc. with fasteners/screws finished with 12. Omm Gypsum sheets joints covered with POP slurry ./tape. Rates shall include painting (One Coat of putty, one coat of primer coat and tow coats of acrylic paints.)

Rates shall include providing necessary cut-outs & additional support frames for electrical fixtures, A.C. grills, vertical drop up to 1'6" etc. item includes finishing with painting base work and finishing in plastic paint



of white colour. (Note:- No extra payment shall be given for design. However, the visible area of the vertical side at the intersection of Gypsum & Armstrong

False ceiling shall be paid.)

675.00 Sft.

Wall Panneling All Sides

495.00 Sft.

Total Rs.

GST 18%

Say

GRAND TOTAL ----

(Rs. ---- Lacs ---- Thousand Only.)

Date :- 01/11/2023

Place :- Varanasi

PROJECT - TENDER FOR ELECTRICAL/DATA CABLING WORKS. BANK - Baroda U.F. Bank BRANCH -Søyepur REGIONAL OFFICE- VARANASI

"ALL WORKS TO BE DONE AS PER TENDER CONDITIONS.

DESCRIPTION OF ITEM	_			
SESSIM MANUAL MICHINE	QTY	UNIT	RATE (Rs.)	AMOUNT (Rs.)
nstallation of 200Amp Kit kat Fuse unit 3 nos with 200 Amp neutral link on				
wooden board (3' x 3') complete with connections (new).	1	Set		1
ELECTRICAL PANEL				
Design, manufacture, providing, storing & installing in position, effecting proper ronnection, testing and commissioning of panel made of 14 SWG, CRCA sheet				
sheet. It shall be dust and vermin proof. It shall have compartmentalized				1
onstruction with bus bar chambers, cable alley, cable glands plate etc. as			_	
equired, duly painted from inside as well outside.				Į.
t shall have the following - MAIN PANEL.				
No. 100 Amp. TPN, MCCB (18 KA breaking capacity), Busbars.				
100 Amp., 3 phase, 4 strips, 415 volts, 50 Hz. copper busbars with colour coded			l	Į.
VC heat shrinkable sleeves. Instruments.				
Nulti function Meter for Voltage, Ampere, Power factor, KWH, Data 1 No. with CT 75/5	1 1	Nos.		
Outgoing,			ľ	
Nos. 63 Amp. TP, MCB (For LDB, PDB, Branch UPS DB,				
ATM UPS DB and Spare Feeder).				
ID AMP DP MCB. 2 Nos (for Glow Sign board, and spare feeder)				
No., 100 Amp. Four Pole Change Over for D.G. Set. (Seperate from the				
vanel) =				
he design of panel should be got approved by the Architect before				
nanufacturing.				
The Job shall be completed, to the satisfaction of the Bank Engineer/Architect.				
IDC. LOD. AVID. AVID. DICT. DID UTION				
JPS I/P, O/P AND DISTRIBUTION 10/32 AMP Industrial socket along with MCB for UPS I/P				
SIND O/P	2	Nos.		
2 way SPN db doubte door (1Nos 32A DPMCB and 10 Nos, 6				
0 16A SPMCB) UPS Power Branch .	9	No.		ľ
ITC of 63 Amp TPN MCB in Encloser complete in all		61:2		
espects as required. (UPS)	11	No.		
ITC of 63Amp Rotary Phase selector switch, complete with RYB indication lifht in	3)	Nos.		
n loser complete in all respects as required.	197	(NOD)		
RAW POWER & FAN, LIGHTING DB & AC DISTRIBUTION				
OARD			y .	



WAY TPN DB Double Door (1 No. 63 AMP TP MCB and 12 Nos. 6-32 AMP. SPMCB)	T			
(For AC, Light system, Power Points) all complete with blanking plates	3;	Nos,		
CABLES				
3.5 Core 35.0 Sq.mm Aluminium Armoured Cable (Electric				
Meter to Electric Panel)	25	Mtr.		
4 X 6.0 Sq.mm Copper Wire + 1X 4.0 Sqmm copper earth wire in PVC Pipe fixing on walls or chassing the walls and making it good with cement mortar of 1:5 ratio metuding Connecting testing etc. compete (Panel to UPS Incomer, LDP, PDB and ATM UPS Incomer).	20	Mtr.		
Same as above but 4 x 10.00 Sqmm Copper Counductor Cable. (Kit Kat fuse unit to AE DB) complete with lugs.	22	Mtr.	=	-
Z X 6.0 Sq.mm Copper Wire (ROTARY SWITCH TO UPS and UPS DB) + 1X 2.5 Sqmm		7,000.5		
good with cement mortar of 1:5 ratio including. Connecting **Pesting etc. compete	60	Mers		
2 & 2.5 Sq.mm Copper Wire (Electric Panel to Glow Sign Board) + 1X 1.5 Sqmm copper earth wire in PVC Pipe fixing on walls or chassing the walls and making it good with cement mortar of 1:5 ratio including. Connecting	25	Mtr.		
AC POINT				
Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire				
6, 20/25 Amp. Metal clad plug & Socket DB complete in all respect as required by the Bank (for 1.0 & 2.0 Tr AC)	5	Nos.		
EARTHING				
P technology GEL type 50mmdia 3000mm long earth electrod.				
2 SWG Bare Copper Earth Wire from earthing pit /Earth terminal to load point	3	Nos.		
UPS DB and Main DB etc)	32	Mtr _k		
IPS POINT				
hipply & Installation of point wiring for Primary UPS or stabilized power plug				
contists on workstations / table for computers using 3 X1.5 Sq.mm copper onductor multi-starnd FR PVC sheathed flexible wire pulled through floor acceways/conduit and taken upto table top using PVC rigid or flexible conduits unwithin wooden/metal partitions. Each point consisting of 2 nos of 10A, 3 pin ockets & 1 No., 20A Switch with socket (Modular) with indicator, wired together priming one point. The earth wire of green color only.	7	Nos.		
	-			
AW POWER POINT			 	

ter

L



OTE -: All work should be done as per Bank's Specification.		GRAND	TOTAL
		TOTA	AL (Rs.)
× 7 W.LED Bulb with holder	4	No.	
all Bell Wireless.	Ti	No.	
xhaust Fan (9") Metal Body	1	Nos.	
nomm Wall Mounted Fan	.7	Nos.	
200mm Ceiling Fan	4	Nos.	
uhe Light(LED) - Pattl Type: (18 watts)	4	Nos.	
Down Lighter 1x12W LED Panel white	18	Nos:	
Supply and Installation of Square light fitting (2' x 2') LED green square hilips Supply and Installation of Square light fitting (2' x 2') LED green square hilips.	18	Nos.	
IXTURES		INOU	
SITC/of 9U rack	i	No.	
24 Port D-Link Switch	1	No.	
Supplying and fixing of 2 mtr long crimped patch cord	7	Nos.	
supplying and laying D-link make GAT-6 Cable complete with CAT-6 information outlet with plate & suface Box at individual Tables	7	Nos.	
Supplying and laying of D-Link make CAT-6 (UTP) cable through trenches / conduits.			
DATA CABLING & POINT			
and a social in the social in this arise board	5	Nos.	
5/10A Switch with 5pin 10A socket in light & fan board	1	Nos.	
Exhaust Fan Point along with 10 AMP modular switch	8	Nos.	
alung with 4/5 step electronic fan regulator. Wall Fan Point along with 10 AMP modular switch	-6		
Celling Fan Point including the cost of 10A modular Switch	2	Nos.	
Primary light points including the cost of 10 A modular switch	35	Nos.	
Supply & Installation of concealed point wiring using 600v grade 1.5 Sq.mm copper conductor PVC insulated wires (with proper R.Y.B. color code.) pulled through heavy gauge PVC conduits laid concealed over false ceiling including 2 Nos. 2.5 sqmm circuit wires from the relevant DB and also including 2.5 sqmm green color copper earth wire and switch plate, switches, etc. as approved by the Bank's Engineer/Architect.			
LIGHT/FAN POINT			
table for computers using 3 X2.5 Sq.mm copper conductor PVC sheathed flexible wire pulled through already laid floor raceways and taken upto table top using PVC rigid or flexible conduits run within wooden/metal partitions. Each point consisting of 1 nos of 16A, 6 pin sockets & 1 No. 15A Switch (Modular), wired together forming one point. The earth wire of green color only.	5	Nos.	



PROJECT - SPECIFICATION FOR FURNITURE WORKS. BANK - BARODA U.P. BANK BRANCH - SOYEPUR REGIONAL OFFICE - VARANASI *ALL WORKS TO BE DONE AS PER TENDER CONDITIONS.

A	FURNITURE ITEMS	
1	LAMINATES (IS-2046) / VENEER	GREEN LAM / CENTURY / ARCHID / FORMICA / SUNMICA
2	COLUMN TOOLS I SURVIVIONE SANDE I	
2	COMMERCIAL PLY (IS-303) / WATERPROOF PLY (IS-710) / BLOCK BOARD (IS-1659) / FLUSH DOOR (IS-2202)	ARCHID/ CENTURY / GREEN /SAMRAT
3	ADHESIVES	FEVICOL/ VAMICOAL
4	LOCKS	GODREJ
	MULTIPURPOSE GROUP LOCK	E-MPL1-22 / E-MPL1C-22 (EBCO)
	NIGHT LATCH	
	CYLINDRICAL LOCK (SS MATT FINISH)	8812 (GODREJ)
	CTEINDRIGAE EOCR(53 MATTENISH)	3792-WITH KEY AND 3786-KEYLESS (GODREJ) / C120SS (EUROPA)
	MORTISE DEAD LOCK (TWO WAY)	8815(GODREJ)
	MORTISE LOCK WITH DOOR HANDLE	MATIZ 8083(GODREJ)
45	DRAWER CHANNELS	GODREJ/HATTICH/OZONE
	TELESCOPIC CHANNELS (ZINK PLATED)	STDS35(I)35/ STDS25(I)35/ STDS50(I)35/ STDS60(I)35
	BOTTOM CHANNELS (POWDER COATED)	BMDS 35/ BMDS 37/ BMDS 55/ BMDS 60 (EBCO)
6	GENERAL HARDWARE	SS MATT FINISH
	DOOR STOPPER	BLACK/IVORY/BROWN/SILVER COLOR POWDER COATED DS1 (EBCO) SPRING TYPE BLACK/BROWN/IVORY COLOR POWDER COATED (ECGL'S STERLING)
	Hinges	I) 3"/4"/5"/6" 1.8MM TH. SS MATT FINISH (SUZU) II) 75X12X19 1.2 MM TH. SS MATT FINISH FOR STORAGE (SUZU) III) AUTO CLOSE HINGES – SLIP ON HINGE- EURO / CLICK ON HINGE-I (EBCO) FOR STORAGE
	HANDLES 'D' OR 'G' TYPE	1) 3"/4"/6"10MM DIA SS 202 MATT FINISH (ANJALI)
; "	TOWER BOLT	3"/4"/6"/8" BRASS EXTRUDED SS MATT FINISH (OSWAL)
	SLIDING CHANNEL	EBCO MAKE APPROVED BY ARCHITEC/BANK.
7	FLOOR SPRING	RITZ,HYPER,EVERITE (ISI Mark)

8	DOOR CLOSURE	RITZ,HYPER,EVERITE (ISI mark)
		and the state of t
9	PATCH FITTINGS FOR DOOR AND FIXED	GODREJ / XL C SERIES(DORMA) / OPF SERIES
	GLASS PARTITION (TOP/BOTTOM PATCH,	(OZONE)
	PIVOT, PATCH LOCK, LARM, L CONNECT,	(SESTIE)
	CONNECTOR, FLOOR	
1000	SORING HANDLE DI ASTIC DECELET	
10	GLASS / MIRRORS	SAINT GOBAIN / MODI
11	ALUMINUM SECTION	JINDAL / HINDALCO
12	WINDOW BLINDS	VISTA / AEROLUX/HUNTER DUGLUS / MAC
13	POLISH / PAINT	ASIAN PAINTS / BERGER / NEROLAC
14	PARTICLE BOARDS	NOVAPAN / KITLAM/DECO BOARD
15	COMPUTER ACCESSORIES	
	CPU HANGER/ SHELF	SIDE MOUNTED IS CPU HL SM (INNOFITT)
	ANISHE WOOD OF THE PERSON NO.	/CPUSM(EBCO),
	CABLE MANAGER (60MM)	I) METAL - CO60ZN1(EBCO)
		II) PVC - CO 60 (EBCO) BLACK/IVORY/GREY COLO
16	ACP PANEL	TIMEX / ALU DECOR / EURO
19	WHITE FILM FOR GLASS	CRYSTAL / SONA MAKE VINYL FROSTED FILM
B	PAINTS	ICI, ASIAN,DULUX, BERGER, NEROLAC, JOHONSO & NICOLSAN
1	ANTI CORROSIVE PAINT	TIKITAR, FINCOAT
2	RED OXIDE	ASIAN, DULUX, NEROLAC
3	POLISH	ASIAN MELAMINE
4	EXTERIOR PAINTS	DULUX WEATHERSHIELD OR APP. EQUIVALENT
5	ENAMEL PAINT	ICI, DULUX, ASIAN, NEROLAC
c	FALSE CEILING	
1	GYPSUM BOARD	GYPROC (SAINT GOBAIN)
2/	FRAMING WITH COMPLETE SYSTEM	GYP STEEL ULTRA (SAINT GOBAIN), RAMCO FUJI
3:	HILUX BOARDS	RAMCO OR APPROVED EQUIVALENT
:4	MINERAL FIBRE TILES CEILING WITH COMPLETE SYSTEM	ARMSTRONG/SAINT GOBAIN/USG

or	OTECT CONCURRENCES TO	
- FR	ROJECT - SPECIFICATION FOR FURNITUE	RE WORKS.
	BANK - BARODA U.P. BANK	
	BRANCH- SOVEPUR	
<u> </u>	REGIONAL OFFICE- VARANASI	
*ALL WORKS TO BE I	DONE AS PER TENDER CONDITIONS.	

	D	APPROVE MAKE LIST FOR ELECTRICAL
--	---	----------------------------------



PVC rigid conduits & Accessories:	1.5 mm thick (MMS) ISI and FIA approved - Precision
	/ Vraj / Nihir / BLP / PFI / Anchor / Polycab make. (
l l	Only white coloured pipes ERLS
	type to be used.).
L.T. Cables:	Havells / KEI / Polycab / Finolex.
Wires (FRLS)	Havells / KEI / Polycab / Finolex.
Main Distribution Boards:	MDS Legrand (Lexic) / Hager / Crabtree XPOA /
	Schneider (Eazy 9) /
	L & T EXORA / C & S Wintrip / Siemens Bitaguard.
ELCB / RCCB / Miniature Circuit Breaker:	MDS Legrand (Lexic) / Hager / Crabtree XPOA /
	Schneider (Eazy 9) /
	L & T EXORA / C & S Wintrip / Siemens Bitaguard.
Switch gears:	MDS Legrand (Lexic) / Hager / Crabtree XPOA /
	Schneider (Eazy 9) /
	L & T EXORA / C & S Wintrip / Siemens Bitaguard.
Change Over Switch:	HPL Socomac/ Havells / L & T / Hager.
Domestic fittings:	The secondary Hovelisty & Carly Hager.
a) All Switching Modular Accessories.	MK Wrapped Wround Plus / Schneider Livia / L.& T
	entis / Crabtree
ľ	Verona / Salzer Elite / Legrand Myris / C & S Divino /
_	SSK Ace.
b) Holders / celling roses	Ancher
c) Adhesive Tape	Bhor (Steel Grip)
10 - 30 A Polycarbonate Socket & Top:	MDS Legrand (Lexic) / Hager / Crabtree XPOA /
1	Schneider (Eazy 9) /
	L&T EXORA / C & S Wintrip / Siemens Bitaguard.
Telephone Wires / Cable!	Finolex / Havelis / L & T / Polycab.
Telephone tag block:	Krone make.
Cable Lugs:	Dowell / Lotus / Jainson / 3 D.
Cable gland Single / Double Compression:	HM1/Comet/3D.
	Processor Comment of Social
Ammeter / Voltmeter:	AE / HPL /MECO/ Enercon make.
Selector switches:	L&T salzer / Kaycee make.
Indicator lamps:	LED type Teknic / Precifine/ Binay.
Connector strips:	Wago / Elmex make.
Lighting Fixtures	Wipro / Philips / GE / Crompton. only
	Khaitan / Crompton / Havelfs.
Ceiling Fan (5 star rated):	Crompton ('High Breeze Plus') / Havells.
	E. FORESSO PURENT PRESTA LIRENT Y LIBAGILLE
(Wall mounted Fan (5 star rated):	Occumption (High Flow Ways) // Planella
Wall mounted Fan (5 star rated): Data Cable - I / O Unit:	Crompton (High Flow Wave) / Havells. D - Link / Digi Link.
	Wires (FRLS): Main Distribution Boards: ELCB / RCCB / Miniature Circuit Breaker: Switch gears: Change Over Switch: Domestic fittings: a) All Switching Modular Accessories. b) Holders / celling roses c) Adhesive Tape 10 - 30 A Polycarbonate Socket & Top: Telephone Wires / Cable: Telephone tag block: Cable Lugs: Cable gland Single / Double Compression: Ammeter / Voltmeter: Selector switches: Indicator lamps: Connector strips: Lighting Fixtures: Exhaust fan (Light duty):

5.2 ys

