

REF: ROVARA: P&E:Tender: 2023-24 Date: 12.03.2024

TENDER FOR ELECTRICAL AND UPS EARTHING WORK IN VARIOUS BRANCHES

Sealed quotations are invited from the EMPANELLED companies/firms for on-site Electrical and UPS Earthing work installed at various branches/offices of our Bank located in Varanasi District under control of Regional Office, Varanasi.

Last Date and time for receipt of Bid: - 02.04.2024 12.00 p.m.

Date and time of opening of Bid Address and communication address: -

Date and Time: 02.04.2024 at 4:00 PM

THE REGIONAL MANAGER.

Baroda U.P. Bank

Regional Office, Varanasi J 12/140, D-1, Gulab Badi,

Chauka Ghat, Varanasi- 221002

E-mail Address: planning.rovara@barodauprrb.co.in

Eligibility:

- 1. The firms/companies should have minimum 3 years of experience in field of site Electrical and UPS Earthing work in PSBs and Financial Institutions.
- 2. The firms/companies should have been registered with Sales Tax Department for work contract and shall provide PAN and GSTIN No. with the bid.
- 3. Firm/Company must have strong support of technical staff to resolve calls within 24 hours.
- **4.** The given Rate will be Valid for 01 year from the date of acceptance of the rates.
- 5. Conditional tenders shall not be accepted on any ground and shall be rejected straight away.
- 6. Any deviation of the conditions laid by the bank will not be accepted and the bid will be rejected without assigning any reasons.
- 7. The entire tender document must be signed with the seal and attached as mark of acceptance of terms and conditions.

Payment Terms:

- 1. No advance payment shall be made in any case.
- 2. Payment will be released on successfully completion of the said work, subject to the vendor submitting to our office, Satisfactory Service Report form all branches.

Bid Submission:

- The sealed tenders must reach the Baroda U.P. Bank Regional Office, J 12/140, D-1, Gulab Badi, Chauka Ghat, Varanasi- 221002. Complete in all respect latest by 12.00 PM on dated 02.04.2024. Bids received after that shall not be entertained.
- Bids must be submitted through hand to hand or through registered Post.
- The bid must contain two Envelopes as per procedure given below.

IF ANY OF THE ABOVE DOCUMENTS IS/ARE NOT SUBMITTED OR IF SUBMITTED BUT IS NOT DULY ATTESTED, THE BID WILL BE REJECTED & PRICE BID WILL NOT BE OPENED. IT MUST BE MENTIONED ON ENVELOPE "DOCUMENT SUBMITTED FOR ELECTRICAL AND UPS EARTHING WORK".

क्षेत्रीय कार्यालय, जे-12 / 140-डी-1, गुलाब बाड़ी, चौकाघाट, वाराणसी-221001,दूरभाष:05 2220102 रिर्मालय Regional Office, J-12/140-D-1, Gulab Badi, Chaukaghat, Varanasi-221001,Telephone: 0542-2201094

e-mail: ROVARA@barodauprrb.co.in



FIRST ENVELOPE MUST CONTAIN ALL THE DOCUMENTS GIVEN BELOW:

- 1. The entire tender document duly signed by the vender as a mark of acceptance of terms and conditions of the tender document.
- General Information of Bidder (Annexure I).
- All documents should be self-attested along with stamp of the Firm.

SECOND ENVELOPE MUST CONTAIN ALL THE DOCUMENTS GIVEN BELOW:

1. The price must be submitted on the prescribed format (Annexure-II). Price bid will not be accepted on any other format or document.

IT MUST BE CLEARLY MENTIONED "PRICE BID FOR ELECTRICAL AND UPS EARTHING WORK"

BOTH TWO ENVELOPES MUST BE KEPT IN THIRD SEALED ENVELOPE AND SUPERSCRIBED "TENDER FOR ELECTRICAL AND UPS EARTHING WORK".

RIGHT TO REJECT BIDS:

- Bank reserves the right to accept or reject any quotation or cancel the entire process at any stage without assigning any reason whatsoever. The bank does not bind itself to accept the lowest of any quotation and reserves to itself the right to accept or reject any or all quotations. Either in whole or part, without assigning any reason for doing so.
- Quoting incredibly low value of items with a view of subverting the tender process shall be rejected straight away.
- The selected bidder is found to be unsatisfactory response/performance.

Request For Information:

• All queries relating to the tender, technical or otherwise must be either in writing or by email only – planning.rovara@barodauprrb.co.in FOR ANY CLARIFICATION CONTACT- Baroda U.P. Bank Regional Office, J 12/140, D-1, Gulab Badi, Chauka Ghat, Varanasi- 221002

Disclaimer:

This Request for Proposal (RFP) document has been prepared solely for the purpose of enabling Baroda UP Bank to select vendor through bidding open for all concerned for comprehensive annual maintenance contract of note counting/authentication machine at its Branches.

The RFP documents is not recommendation, offer or invitation to enter into a contract, is subject to observance of selection process and appropriated documentation being agreed between the Bank and any successful bidder as identified by the Bank, after completion of the selection process as detailed in this document.

Yours Faithfully

(Manoj Kumar Jha) Regional Manager

क्षेत्रीय कार्यालय, जे-12 / 140-डी-1, गुलाब बाड़ी, चौकाघाट, वाराणसी-221001,दूरभाष:0542-2201094
Regional Office, J-12/140-D-1, Gulab Badi, Chaukaghat, Varanasi-221001,Telephone: 0542-2201094
e-mail: ROVARA@barodauprrb.co.in



Annexure-I

Pre-Qualification Profile

Name of the Firm/Company	
Address (Head Office)	
Phone No.	
Year of Establishment	
Name of Proprietor or Name of Partner/Director/Associates	
Details and Value of major work taken up during the last 3 yrs. with reputed financial organization /banks	
List of other major customers (Work Order/ Experience/ Service certificate to the effect from the customers are to be enclosed)	
PAN Number (for TDS)	
GSTIN No. (Certificate attached)	
Any other relevant information with documents	

DETAILS OF INFRASTRUCTURE AVAILABLE

Authorized Seller Dealership (Yes/NO)	
Authorized Seller Dealership (165/NO)	

Signature of Authorized Signatory



Annexue II

Detail Tender for 40 Branch Earthing work of Varanasi Region Branch-Baroda U.P. Bank Ro-Varanasi

t h c c s v iii				Rs. P.	Rs. P.
t h c c r c s v iii					
r c s v	S/F of UPS earthing-S/burying of Dual pipe	40x2=80	No		
	technology (Pipe in Pipe) earthing electrode	2			
r c s v	having GI 80mm O/D pipe with 25 micron	Earthing		ļ ·	1
c s v	coating, 3metres long. The space between two	per			
s .v .ii	pipes to be filled with Highly conducive & Non	Branch			
.v	corrosive chemical compound. The vacant				
i	space between pipe & hole shall also be filled				-
	with Compound all around. The job also				
	includes S/F of GI strip clamp with two holes				· {
	(with SS/GI bolts & nuts) on the electrode&				
ta	taking two earthing leads of 4mm dia copper		·	,	
V	wire (Assumed length of 10m -beyond 10m to			٠.	
b	be paid extra)upto Main panel complete in all				
r	respects with guaranteed E/N voltage of less				
tl	than 2 volts and resistance less tahn 1 ohms.				1
Γ [The 4mm dia Cu. earth wire shall be terminated				
o	on a separate 6way earthlink. The connections		' '		
	for Panel earthing & earth bus in the panel		}		
	should be taken from this earthlink				

*	lRs.	 Lacs	 Thousand	Only.
			*	

Date :- 11-03-2024 Place :- Varanasi

